

STATEMENT ACCOMPANYING FORM-A.

1. Name and Door No. of Building **Ms. THIRUTHANGAL NADAR VIDHYALAYA,**
2. Location (Street Name, Ward No., Name of Place (Corporation, Municipality, Panchayat, Panchayat Union, Township, Cantonment) **No. 1051, T. H Road, Thiruvottiyur, Chennai - 600 019.**
RS. No. 185 & 186, Thiruvottiyur High Road, Thiruvottiyur Taluk, Thiruvallore District.
3. Year of Construction **GF & FF 2010; SF & TF 2012.**
4. Approximate Cost of Construction **About Rs. 5.70 Crores.**
5. Purpose for which the building is being used or purpose to be used **School**
6. Purpose for which the building hitherto been used **— do —**
7. Details of construction of the building (particulars) of the foundation soil, specification of the various parts under
1. Foundation: **Isolated RCC column footings**
2. Basement: **Brick work in CM over RCC plinth beams**
3. Superstructure: **Four storied (GF+FF+SF+TF), RCC framed structure with brick walls in CM plastered over with CM on both sides. It has mostly marble / partly shabad stone & ceramic tiled floorings. (Small area in GF at North East corner has pre coated metal sheet roofing with false ceiling and pre coated metal sheet cladding).
Total Carpet Area is about 38,200 Sq. Ft.**
4. Floor and Roof (are to be given):
8. Period for which license is required: **27-12-2018 to 26-12-2021(Three Years)**
9. Number of persons to be accommodated: **3820 Persons**

Dated: 29.12.18



Principal

THIRUTHANGAL NADAR VIDHYALAYANo: 1051, T.H. ROAD,
THANGAL. CHENNAI-600 019

Dr. B. N. Gupta
Dr. B. N. GUPTA B.E.M.Sc.(Engg) Ph.D.
 FIE, FIV, FICS, MISET
 Registered Valuer
 No.6, Damodara Murthy Road,
 Kilpauk, Chennai-600 010.
 Ph: 2353 7146 (O) & 26443164 (R)
 Mobile: 9849321653

For Thiruthangal Nadar Vidhyalaya

Signature of the Owner of the Building

Secretary & Correspondent

FORM - B

I certify that the building of M/s. THIRUTHANGAL NADAR VIDHYALAYA,
No. 1051, T. H Road, Thiruvottiyur, Chennai - 600 019 was inspected
27-12-2018 mentioned in the statement below. I have satisfied myself that the
 building structurally sound to be used as a Public Building for the purposes
 noted in the statement. The structural soundness of the building has been
 verified taking into account the loading as per the latest Indian Standards IS:
 895. The scope of this Stability Certificate is limited only to the structural
 soundness of the subject building (and no other structure in the premises) as per
 BIS 456 - 2000; this does not include the eventualities caused by natural
 calamities like cyclone, earthquakes, high gales & storm, lightening, floods, fire
 etc. Certified that no thatched buildings are used in the premises.



B. N. Gupta
 Dr B N GUPTA BEM Sc(Engg) Ph.D
 FIE FIV FIGS MISET
 Chartered (B. N. Gupta) Regd Valuer
 No.6, Damodara Murthy Road,
 Kilpauk, Chennai-600 010.
 Ph: 2363 7146 (C) & 23443164 (R)
 Mobile: 9840631653

If any thatched buildings are constructed after the issue of this license, we are
 held responsible for any fire accident that occurs later and that we are aware
 that our license will be cancelled.

Signature of the Owner of the Building

For Thiruthangal Nadar Vidhyalaya

[Signature]
 Secretary & Correspondent

[Signature]
 Principal
 THIRUTHANGAL NADAR VIDHYALAYA
 No: 1051, T.H. ROAD,
 THANGAL, CHENNAI-600 019

FORM - C

(Form of certificate of structural soundness under sub-section (4) of Section 4 of the Tamil Nadu Public Building (Licensing) Act 1965 (Tamil Nadu Act 1 of 1965) referred to in Rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.

EEEEEEEE

I certify that the building mentioned in the statement and furnished below the salient technical features was inspected.

1. Foundation:

- i. Depth below ground level: 2.13 M
- ii. Nature of soil set out in the foundation level: Sandy soil
- iii. Pressure at foundation: About 12.00 t/Sq.m.
- iv. Probable safe bearing capacity of strata met at the foundation: About 16.00 t/Sq.m.

2. Superstructure:

- | | | |
|--|---------------------|-------------------|
| i. Maximum stress in the most critical section of masonry and concrete | a. Brick Work in CM | = 0.75 kg/Sq.cm |
| | b. RCC | = 30.00 kg/sq.cm. |
| ii. Nature of masonry and concrete and its safe permissible stress | a. Brick Work in CM | = 5.00 kg/Sq.cm |
| | b. RCC | = 50.00 kg/Sq.cm |

The structural soundness of the building has been verified by me with reference to BIS loading standards BIS: 895 (latest version) and other relevant Indian Standard code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period from 27-12-2018 to 26-12-2021 (Three Years).

Date: 29.12.18

Place: Chennai 10



(Signature)
Dr. B. N. GUPTA B.E.M. Sc(Engg) Ph.D
 Chartered Engineer & Regd Valuer
 No.6, Damodara Murthy Road,
 Kilpauk, Chennai-600 010.
 Ph: 2383 7146 (O) & 26443164 (R)
 Mobile: 9240531653

(Signature)

Principal
THIRUTHANGAL NADAR VIDHYALAYA
 No: 1051, T.H. ROAD,
 THANGAL, CHENNAI-600 019

For Thiruthangal Nadar Vidhyalaya


(Signature)
 Secretary & Correspondent

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the building, Door No., Street Name, and Name of the Place (1)	Age of the Building (2)	Value of Building at Current Rates (3)	No. of Stories (4)	Short description of structure Steel, RCC framed or Load Bearing in Masonry (5)
---	----------------------------	---	-----------------------	--


M/s. THIRUTHANGAL NADAR VIDHYALAYA, No. 1051, T. H Road, Thiruvottiyur, Chennai - 600 019.	GF, FF = 8 and SF&TF = 6 years	About Rs. 5.70 crores.	Four	Four storied (GF+FF+SF+TF), RCC framed structure with brick walls in CM plastered over with CM on both sides. It has mostly marble / partly shabad stone & ceramic titled floorings. (Small area in GF at North East corner has pre coated metal sheet roofing with false ceiling and pre coated metal sheet cladding).
--	--------------------------------------	------------------------	------	---

Purpose for which the building is Certified for use. (6)	Period for which the building will be structurally sound (7)	No. of Persons to be accommodated (8)	Remarks (9)
School	27-12-2018 to 26-12-2021 (Three Years)	3820 persons	Building is structurally sound


 29/12/18
 Signature of the Engineer
 Designation.



Dr. B. N. GUPTA B.E. M. Sc (Engg) Ph.D.
 FIE FIV FIGS MISET
 Chartered Engineer & Regd Valuer
 No.6, Damodara Murthy Road,
 Kilpauk, Chennai-600 010.
 Ph: 2363 7148 (O) & 26443164 (R)
 Mobile: 9840531653


 Principal
THIRUTHANGAL NADAR VIDHYALAYA
 No: 1051, T.H. ROAD,
 THANGAL, CHENNAI-600 019

For Thiruthangal Nadar Vidhyalaya


 Secretary & Correspondent

FORM - E

(Form of Report to be made to the competent authority by inspecting authorities or officers appointed under other act under Section 25 of Madras Public Buildings Authorities Act 1965 (Madras act 13 of 1965) Referred to in rule 7 of the Madras Public Buildings Licensing Rule, 1966.

EEEEEEEE

- | | |
|--|---|
| 1. Name and Designation of inspecting authority or officer appointed or having jurisdiction under any other act or law. | B N Gupta, Panel Engineer,
(Class IA) of Collector of Chennai for
Issuing Certificate of structural soundness
of the public buildings. |
| 2. Location of the building inspected D. No., Street name of place, ie., Municipal Corp. / Municipality / Panchayat / Panchayat Union / Township / Cantonment. | MS. THIRUTHANGAL NADAR VIDHYALAYA,
No. 1051, T. H Road,
Thiruvottiyur, Chennai - 600 019. |
| 3. Date of Inspection | 27-12-2018. |
| 4. Purpose for Which the building is used | School |
| 5. Nature of Defects noticed | -- Nil -- |
| 6. Suggestion for rectifying defects | -- Nil -- |
| 7. If in a dangerous conditions immediate action Recommended to be taken. | -- Nil -- |

Date: 29.12.18

Place: Chennai-10.

Signature of Inspecting Authority /
Officers appointed or jurisdiction



Dr B N GUPTA B.E.M.Sc(Engg) Ph.D.
FIE FIV FGS MASET
Chartered Engineer & Regd Valuer
No.6, Damodara Murthy Road,
Kilpauk, Chennai-600 010.
Ph: 2363 7146 (O) & 26443164 (R)
Mobile: 9840631653.


Principal
THIRUTHANGAL NADAR VIDHYALAYA
No: 1051, T.H. ROAD,
THANGAL. CHENNAI-600 019.

For Thiruthangal Nadar Vidhyalaya


Secretary & Correspondent

STATEMENT ACCOMPANYING FORM-A.

- | | |
|--|---|
| 1. Name and Door No. of Building | M/s. THIRUTHANGAL NADAR VIDHYALAYA, |
| 2. Location (Street Name, Ward No., Name of Place (Corporation, Municipality, Panchayat , Panchayat Union, Township, Cantonment) | No. 1050/9, T. H Road,
Thiruvottiyur, Chennai – 600 019.

Old Survey No.185part &186 part and TS No.96/17part Thiruvottiyur Village.(As given in the Sale deed page No.3,of Document No.3223 of 2019 of the Sub-Registrars Office...11-04-2019). |
| 3. Year of Construction | 2018-19 |
| 4. Approximate Cost of Construction | About Rs. 77.00 Laksh |
| 5. Purpose for which the building is being used or purpose to be used | School |
| 6. Purpose for which the building hitherto been used | --- do --- |
| 7. Details of construction of the building (particulars) of the foundation soil, specification of the various parts under | |
| 1. Foundation: | Isolated RCC column footings |
| 2. Basement: | Brick work in CM over RCC plinth beams |
| 3. Superstructure: | Three storied (GF+FF+SF), RCC framed structure with brick walls in CM . It has mostly granite flooring . |
| 4. Floor and Roof (are to be given): | Total Carpet Area is about 3,825 Sq. Ft. |
| 8. Period for which license is required: | 10-11-2020 to 09-11-2023(Three Years) |
| 9. Number of persons to be accommodated: | 383 Persons |

Dated: 18.11.2020



Dr. B. N. GUPTA B.E.M.Sc(Engg) Ph.D
Signature of the Engineer A.I.S.E.T
Chartered Engineer & Regd Valuer
No.6, Damodara Murthy Road,
Kilpauk, Chennai-600 010.
Ph: 2363-7146 (O) & 26443164 (R)
Mobile: 98405 31653

Signature of the Owner of the Building

Principal

THIRUTHANGAL NADAR VIDHYALAYA

No: 1051, T.H. ROAD,
THANGAL, CHENNAI-600 019

For Thiruthangal Nadar Vidhyalaya

Secretary & Correspondent

FORM - B

I certify that the building of M/s. THIRUTHANGAL NADAR VIDHYALAYA, No. 1050/9, T. H Road, Thiruvottiyur, Chennai - 600 019 was inspected 10-11-2020 mentioned in the statement below. I have satisfied myself that the building structurally sound to be used as a Public Building for the purposes noted in the statement. The structural soundness of the building has been verified taking into account the loading as per the latest Indian Standards IS: 895. The scope of this Stability Certificate is limited only to the structural soundness of the subject building (and no other structure in the premises) as per BIS 456 - 2000; this does not include the eventualities caused by natural calamities like cyclone, earthquakes, high gales & storm, lightening, floods, fire etc. Certified that no thatched buildings are used in the premises.



Signature of the Engineer.



Dr B N GUPTA BE M Sc(Engg) Ph D
FIE FIV FIGS MISET
Chartered Engineer & Regd Valuer
No.6, Damodara Murthy Road,
Kilpauk, Chennai-600 010.
Ph: 2363 7146 (C) & 26443164 (R)
Mobile: 98406 31653

Certified that no addition or alteration has been made to existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a license if the purpose for which the license was granted for the use of the building or a portion of the building originally is changed or altered subsequently.

If any thatched buildings are constructed after the issue of this license, we are held responsible for any fire accident that occurs later and that we are aware that our license will be cancelled.

Date:

Signature of the Owner of the Building



Principal

THIRUTHANGAL NADAR VIDHYALAYA
No: 1051, T.H. ROAD,
THANGAL. CHENNAI-600 019

For Thiruthangal Nadar Vidhyalaya



Secretary & Correspondent

FORM - C

(Form of certificate of structural soundness under sub-section (4) of Section 4 of the Tamil Nadu Public Building (Licensing) Act 1965 (Tamil Nadu Act 1 of 1965) referred to in Rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.

εεεεεεεεε

I certify that the building mentioned in the statement and furnished below the salient technical features was inspected.

1. Foundation:

- i. Depth below ground level: 2.13 M
- ii. Nature of soil set out in the foundation level: Sandy soil
- iii. Pressure at foundation: About 9.00 t/Sq.m.
- iv. Probable safe bearing capacity of strata met at the foundation: About 16.00 t/Sq.m.


2. Superstructure:

- i. Maximum stress in the most critical section of masonry and concrete
- | | |
|---------------------|------------------|
| a. Brick Work in CM | = 0.75 kg/Sq.cm |
| b. RCC | = 30.00 kg/sq.cm |
- ii. Nature of masonry and concrete and its safe permissible stress
- | | |
|---------------------|------------------|
| a. Brick Work in CM | = 5.00 kg/Sq.cm |
| b. RCC | = 50.00 kg/Sq.cm |

The structural soundness of the building has been verified by me with reference to BIS loading standards BIS: 895 (latest version) and other relevant Indian Standard code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period from 10-11-2020 to 09-11-2023(Three Years).

Date: 18.11.2020

Place: Chennai-10



Signature of the Engineer



Dr B N GUPTA BE M Sc(Engg) Ph D
FIE FIV FIGS MISET
Chartered Engineer & Regd Valuer
No.6, Damodara Murthy Road,
Kilpauk, Chennai-600 010,
Ph: 2363 7146 (O) & 26443164 (R)
Mobile: 98406 31653



Principal

THIRUTHANGAL NADAR VIDHYALAYA

No: 1051, T.H. ROAD,
THANGAL. CHENNAI-600 019

For Thiruthangal Nadar Vidhyalaya




Secretary & Correspondent

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the building, Door No., Street Name, and Name of the Place (1)	Age of the Building (2)	Value of Building at Current Rates (3)	No. of Stories (4)	Short description of structure Steel, RCC framed or Load Bearing in Masonry (5)
---	----------------------------	---	-----------------------	--

M/s. THIRUTHANGAL NADAR VIDHYALAYA, No. 1050/9, T. H Road, Thiruvottiyur, Chennai - 600 019.	About 1 year.	About Rs.77.00 Laksh	Three	Three storied (GF+FF+SF), RCC framed structure with brick walls in CM . It has mostly granite flooring.
---	---------------	----------------------	-------	--

Purpose for which the building is Certified for use. (6)	Period for which the building will be structurally sound (7)	No. of Persons to be accommodated (8)	Remarks (9)
School	10-11-2020 to 09-11-2023 (Three Years)	383 persons	Building is structurally sound


18.11.2020

Signature of the Engineer
Designation.



Dr B N GUPTA BE M.Sc(Engg) Ph D
FIE FIV FIGS MISET
Chartered Engineer & Regd Valuer
No.6, Damodara Murthy Road,
Kilpauk, Chennai-600 010.
Ph: 2363 7146 (O) & 26443164 (R)
Mobile: 98406 31653


Principal

THIRUTHANGAL NADAR VIDHYALAYA
No: 1051, T.H. ROAD,
THANGAL. CHENNAI-600 019

For Thiruthangal Nadar Vidhyalaya


Secretary & Correspondent

FORM – E


(Form of Report to be made to the competent authority by inspecting authorities or officers appointed under other act under Section 25 of Madras Public Buildings Authorities Act 1965 (Madras act 13 of 1965) Referred to in rule 7 of the Madras Public Buildings Licensing Rule, 1966.

EEEEEEEE

- | | |
|--|---|
| 1. Name and Designation of inspecting authority or officer appointed or having jurisdiction under any other act or law. | : B N Gupta, Panel Engineer,
(Class IA) of Collector of Chennai for
Issuing Certificate of structural soundness
of the public buildings. |
| 2. Location of the building inspected D. No., Street name of place, ie., Municipal Corp. / Municipality / Panchayat / Panchayat Union / Township / Cantonment. | : M/s. THIRUTHANGAL NADAR VIDHYALAYA
No. 1050/9, T. H Road,
Thiruvottiyur, Chennai – 600 019. |
| 3. Date of Inspection | : 10-11-2020. |
| 4. Purpose for Which the building is used | : School |
| 5. Nature of Defects noticed | : -- Nil -- |
| 6. Suggestion for rectifying defects | : -- Nil -- |
| 7. If in a dangerous conditions immediate action Recommended to be taken. | : -- Nil -- |

Date: 18.11.2020

Place: Chennai-10



Signature of Inspecting Authority /
Officers appointed or jurisdiction.



Dr B N GUPTA BE M Sc(Engg) Ph D
FIE FIV FIGS MISET
Chartered Engineer & Regd Valuer
No.6, Damodara Murthy Road,
Kilpauk, Chennai-600 010.
Ph: 2363 7146 (O) & 26443164 (R)
Mobile: 98406 31653



Principal

THIRUTHANGAL NADAR VIDHYALAYA

No: 1051, T.H. ROAD,

THANGAL. CHENNAI-600 019

For Thiruthangal Nadar Vidhyalaya



Secretary & Correspondent

STATEMENT ACCOMPANYING FORM-A.

- | | |
|--|--|
| 1. Name and Door No. of Building | M/s. THIRUTHANGAL NADAR VIDHYALAYA, |
| 2. Location (Street Name, Ward No., Name of Place (Corporation, Municipality, Panchayat, Panchayat Union, Township, Cantonment)) | No. 1050/11&12, T. H Road,
Thiruvottiyur, Chennai – 600 019.

Survey No: T S No.96/5, Thiruvottiyur Village.(As per the Sale deed, Document No.8061 (page 3) of 2019 of Sub Registrar Office... 14.10.2019).. |
| 3. Year of Construction | 2019-20 |
| 4. Approximate Cost of Construction | About Rs.1.65 Crores. |
| 5. Purpose for which the building is being used or purpose to be used | School |
| 6. Purpose for which the building hitherto been used | --- do --- |
| 7. Details of construction of the building (particulars) of the foundation soil, specification of the various parts under | |
| 1. Foundation: | Isolated RCC column footings |
| 2. Basement: | Brick work in CM over RCC plinth beams |
| 3. Superstructure: | Three storied (GF+FF+SF), RCC framed structure with brick walls in CM . It has mostly granite flooring. |
| 4. Floor and Roof (are to be given): | Total Carpet Area is about 8,360 Sq. Ft. |
| 8. Period for which license is required: | 10-11-2020 to 09-11-2023(Three Years) |
| 9. Number of persons to be accommodated: | 836 Persons |

Dated: 18.11.2020



Dr. B. N. Gupta
Dr B N GUPTA BEM Sc(Engg) Ph D
Signature of the Engineer, IGS MISET
Chartered Engineer & Regd Valuer
No.5, Damodara Murthy Road,
Kilpauk, Chennai-600 010.
Ph: 2363 7146 (O) & 26443164 (R)
Mobile: 98406 31653

Signature of the Owner of the Building

[Signature]
Principal
THIRUTHANGAL NADAR VIDHYALAYA
No: 1051, T.H. ROAD,
THANGAL, CHENNAI-600 010

For Thiruthangal Nadar Vidhyalaya

[Signature]
Secretary & Correspondent

FORM - B

I certify that the building of M/s. THIRUTHANGAL NADAR VIDHYALAYA, No. 1050/11&12, T. H Road, Thiruvottiyur, Chennai - 600 019 was inspected 10-11-2020 mentioned in the statement below. I have satisfied myself that the building structurally sound to be used as a Public Building for the purposes noted in the statement. The structural soundness of the building has been verified taking into account the loading as per the latest Indian Standards IS: 895. The scope of this Stability Certificate is limited only to the structural soundness of the subject building (and no other structure in the premises) as per BIS 456 - 2000; this does not include the eventualities caused by natural calamities like cyclone, earthquakes, high gales & storm, lightening, floods, fire etc. Certified that no thatched buildings are used in the premises.



Signature of the Engineer.




Dr B N GUPTA BE M Sc(Engg) Ph D
FIE FIV FIGS MISET
Chartered Engineer & Regd Valuer
No.6, Damodara Murthy Road,
Kilpauk, Chennai-600 010.
Ph: 2363 7146 (O) & 26443164 (R)
Mobile: 98406 31653

Certified that no addition or alteration has been made to existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a license if the purpose for which the license was granted for the use of the building or a portion of the building originally is changed or altered subsequently.

If any thatched buildings are constructed after the issue of this license, we are held responsible for any fire accident that occurs later and that we are aware that our license will be cancelled.

Date:

Signature of the Owner of the Building



Principal
THIRUTHANGAL NADAR VIDHYALAYA
No: 1051, T.H. ROAD,
THANGAL. CHENNAI-600 010

For Thiruthangal Nadar Vidhyalaya



Secretary & Correspondent

FORM - C

(Form of certificate of structural soundness under sub-section (4) of Section 4 of the Tamil Nadu Public Building (Licensing) Act 1965 (Tamil Nadu Act I of 1965) referred to in Rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.

εεεεεεεεεε

I certify that the building mentioned in the statement and furnished below the salient technical features was inspected.

1. Foundation:

- i. Depth below ground level: 2.13 M
- ii. Nature of soil set out in the foundation level: Sandy soil
- iii. Pressure at foundation: About 12.00 t/Sq.m.
- iv. Probable safe bearing capacity of strata met at the foundation: About 16.00 t/Sq.m.


2. Superstructure:

- i. Maximum stress in the most critical section of masonry and concrete
 - a. Brick Work in CM = 0.75 kg/Sq.cm
 - b. RCC = 30.00 kg/sq.cm
- ii. Nature of masonry and concrete and its safe permissible stress
 - a. Brick Work in CM = 5.00 kg/Sq.cm
 - b. RCC = 50.00 kg/Sq.cm

The structural soundness of the building has been verified by me with reference to BIS loading standards BIS: 895 (latest version) and other relevant Indian Standard code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period from 10-11-2020 to 09-11-2023(Three Years).

Date: 18.11.2020

Place: Chennai-10



Signature of the Engineer



Dr B N GUPTA BE M Sc(Engg) Ph D
FIE FIV FIGS MISET
Chartered Engineer & Regd Valuer
No.6, Damodara Murthy Road,
Kilpauk, Chennai-600 010.
Ph: 2363 7146 (O) & 26443164 (R)
Mobile: 98406 31653



Principal

THIRUTHANGAL NADAR VIDHYALAYA
No: 1051, T.H. ROAD,
THANGAL, CHENNAI-600 019

For Thiruthangal Nadar Vidhyalaya



Secretary & Correspondent

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the building, Door No., Street Name, and Name of the Place (1)	Age of the Building (2)	Value of Building at Current Rates (3)	No. of Stories (4)	Short description of Structure Steel, RCC framed or Load Bearing in Masonry (5)
---	----------------------------	---	-----------------------	--

THIRUTHANGAL NADAR VIDHYALAYA, No. 1050/11&12, T. H Road, Thiruvottiyur, Chennai - 600 019.	New Construction	About Rs.1.65 Crores.	Three	Three storied (GF+FF+SF), RCC framed structure with brick walls in CM. It has mostly granite flooring.
---	------------------	-----------------------	-------	--

Purpose for which the building is Certified for use. (6)	Period for which the building will be structurally sound (7)	No. of Persons to be accommodated (8)	Remarks (9)
---	---	--	----------------

School	10-11-2020 to 09-11-2023 (Three Years)	836 persons	Building is structurally sound
--------	--	-------------	--------------------------------

B N Gupta
18.11.2020

Signature of the Engineer
Designation.



Dr B N GUPTA BE M Sc(Engg) Ph D
FIE FIV FIGS MISET
Chartered Engineer & Regd Valuer
No.6, Damodara Murthy Road,
Kipauk, Chennai-600 010.
Ph: 2363 7146 (O) & 26443164 (R)
Mobile: 98406 31653

[Signature]
Principal

THIRUTHANGAL NADAR VIDHYALAYA
No: 1051, T.H. ROAD,
THANGAL. CHENNAI-600 010

For Thiruthangal Nadar Vidhyalaya

[Signature]
Secretary & Correspondent


FORM - E

(Form of Report to be made to the competent authority by inspecting authorities or officers appointed under other act under Section 25 of Madras Public Buildings Authorities Act 1965 (Madras act 13 of 1965) Referred to in rule 7 of the Madras Public Buildings Licensing Rule, 1966.

EEEEEEEE

1. Name and Designation of inspecting authority or officer appointed or having jurisdiction under any other act or law. : B N Gupta, Panel Engineer, (Class IA) of Collector of Chennai for Issuing Certificate of structural soundness of the public buildings.
2. Location of the building inspected D. No., Street name of place, ie., Municipal Corp. / Municipality / Panchayat / Panchayat Union / Township / Cantonment. : M/s. THIRUTHANGAL NADAR VIDHYALAYA, No. 1050/11&12, T. H Road, Thiruvottiyur, Chennai - 600 019.
3. Date of Inspection : 10-11-2020.
4. Purpose for Which the building is used : School
5. Nature of Defects noticed : -- Nil --
6. Suggestion for rectifying defects : -- Nil --
7. If in a dangerous conditions immediate action Recommended to be taken. : -- Nil --

Date: 18.11.2020
Place: Chennai-10



Signature of Inspecting Authority /
Officers appointed or jurisdiction.



Dr B N GUPTA BE M Sc(Engg) Ph D
FIE FIV FIGS MISET
Chartered Engineer & Regd Valuer
No.6, Damodara Murthy Road,
Kilpauk, Chennai-600 010.
Ph: 2363 7146 (O) & 26443164 (R)
Mobile: 98406 31653



Principal
THIRUTHANGAL NADAR VIDHYALAYA
No: 1051, T.H. ROAD,
THANGAL, CHENNAI-600 019

For Thiruthangal Nadar Vidhyalaya



Secretary & Correspondent